

# ATTESTATION

Number **WG / 2023 / 805K/ 2**

**Manufacturer:** Przedsiębiorstwo Produkcyjno Handlowe Kostrzewa Spółka Jawna, ul. Przemysłowa 11A, 11-500 Giżycko

**Product:** Heating boiler for solid fuel with automatic stoking

**Trade designation:** **MINI BIO NE with a power of 10 kW**

**Fuel:** wood pellets

**Boiler category:** 1

**Condensing boiler** NO

**Test method:** PN-EN 303-5:2021-09

**Boiler class** 5

		Parameter	Symbol	Unit	Valu	Criterion
Emissions	Nominal heat output	Carbon monoxide	$E_{CO}$	$mg/m^3_n$	116,35	$\leq 500$
		Nitrogen oxides, calculated as $NO_2$	$E_{NOx}$	$mg/m^3_n$	140,70	-
		Organic gaseous compounds	$E_{OGC}$	$mg/m^3_n$	3,86	$\leq 20$
		Dust	$E_{PM}$	$mg/m^3_n$	14,60	$\leq 40$
	Minimum heat output	Carbon monoxide	$E_{CO}$	$mg/m^3_n$	212,74	$\leq 500$
		Nitrogen oxides, calculated as $NO_2$	$E_{NOx}$	$mg/m^3_n$	127,87	-
		Organic gaseous compounds	$E_{OGC}$	$mg/m^3_n$	6,71	$\leq 20$
		Dust	$E_{PM}$	$mg/m^3_n$	18,08	$\leq 40$
	Seasonal	Carbon monoxide	$E_{s,CO}$	$mg/m^3_n$	198,28	$\leq 500$
		Nitrogen oxides, calculated as $NO_2$	$E_{s,NOx}$	$mg/m^3_n$	129,79	$\leq 200$
		Organic gaseous compounds	$E_{s,OGC}$	$mg/m^3_n$	6,28	$\leq 20$
		Dust	$E_{s,p}$	$mg/m^3_n$	17,56	$\leq 40$
Heat properties	Seasonal space heating energy efficiency in active mode		$\eta_{son}$	%	85,80	-
	Seasonal space heating energy efficiency		$\eta_s$	%	81,08	$\geq 75$
	Nominal heat output	Generated useful heat	$P_n$	kW	10,13	-
		Useful efficiency	$\eta_n$	%	85,73	-
		Efficiency	$\eta_{cn}$	%	92,62	$\geq 88$
	Minimum heat output	Generated useful heat	$P_p$	kW	2,89	-
		Useful efficiency	$\eta_p$	%	85,81	-
Efficiency		$\eta_{cp}$	%	93,20	$\geq 87,48$	
Electrical characteristics	Auxiliary electricity consumption Load I		$e_{l,max}$	kW	0,054	-
	Auxiliary electricity consumption Load II		$e_{l,min}$	kW	0,019	-
	Auxiliary electricity consumption in standby mode		$P_{SB}$	kW	0,0024	-
	Energy efficiency index		$E_{EI}$	-	119,69	-
	Energy efficiency class		-	-	A+	-

\*) the emissions listed above are related to dry exhaust gas containing 10% oxygen in the normal state, at a temperature of 273.15K and a pressure of 1013.25 mbar

Comparison of the results of the completed test, registered under number B/2023/805K in the Accredited Testing Laboratory No. AB024 with the requirements of the PN-EN 303-5:2021-09 standard for Class 5 in which the requirements of Commission Regulation (EU) 2015/1189 were implemented of April 28, 2015 on the implementation of Directive 2009/125/EC of the European Parliament and of the Council and Commission Delegated Regulation (EU) 2015/1187 of 27 April 2015 with regard to the requirements for solid fuel boilers.

LABORATORY MANAGER  
Heating Equipment Laboratory

*dr inż. Bartosz Węcki*



THE DEPUTY MANAGING  
DIRECTOR

*dr inż. Maciej Jodkowski*

Katowice, 18.08.2023 r.

Zakłady Badań i Atestacji "ZETOM" im. Prof. F. Stauba w Katowicach sp. z o.o.

ul. Ks. Bpa H. Bednorza 17, 40-384 Katowice, tel.: 0048 32 256 92 57, tel/fax: 0048 32 2569 305, e-mail: biuro@zetom.eu